

Certificate of Product Approval

Certificate Number: 1330a-(cl-7) Issue: 01

Zhongshan Guta Fire Equipment Technology Co., Ltd

4/F, 10#, Xingye Road Huoju District Zhongshan City Guangdong Province 528400 China



s certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Beam Detectors AW-8K901 (refer to Appendix for details)

Standards

EN 54-12: 2015

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Stored for BRE Global Ltd

P Halligan

16 April 2020

16 May 2018

Date of First Issue





This certificate and appendix remains the property of BIEE Global Ltd. and is issued subject to terms and conditions (for details with <u>weeks rediposition.com/farms)</u> To check the validity of this certificate and appendix please wist <u>weeks rediposition.com/farck</u>, soon the QR top or centact us.

BRE Global Ltd, Warford, WD25 SIOX T: +44 (0333 321 8811 E: grauces@bregiobal.com

LPC8 is a Registered Trademark of the Building Research Establishment Ltd.





Appendix to Certificate No: 1330a-(cl-7) Issue: 01 Zhongshan Guta Fire Equipment Technology Co., Ltd

Certified Product	Description	LPCB Ref.No.
AW-BK901	Conventional Reflective Beam Detector (Asenware) Notes: 1. Meets the requirements of EN 54-12: 2015 at the following sensitivity settings: - Level 1: 2.6 dB High sensitivity - Level 2: 3.8 dB Medium sensitivity - Level 3: 5.8 dB Low sensitivity	1330a/01
	Suitable for use at the following separation ranges: Span 1: 8 to 20 meters Short Path (1 x mirror reflector required) Span 2: 20 to 40 meters Short Path (1 x mirror reflector required) Span 3: 40 to 70 meters Normal Path (4 x mirror reflector required) Span 4: 70 to 100 meters Long Path (4 x mirror reflector required)	

Accessories

Mounting Bracket TX7130-R 1 x Mirror Reflector TX7130-R 4 x Mirror Reflector

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



P Halligan

16 April 2020 Date of Issue

16 May 2018

sed for BRE Global Ltd



This certificate and appendix remains the property of BRE Global Ltd. and is issued. subject to terms and conditions (for details visit your redbooklie

To check the validity of this certificate and appendix please visit. you we redbook fee complifieds, scan the QR tag or contact us.

BRE Global Ltd, Worford, W025 90X T. +44 (01833 321 8811 E. gogunes@broglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

