

## Certificate of Product Approval

Certificate Number: 1395c

Issue: 03

Zhongshan Guta Fire Equipment  
Technology Co Ltd

4/F 10# Xingye Road,  
Huoju District,  
Zhongshan City,  
Guangdong,  
528400  
China



is certified by BRE Global Ltd, and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

**Products****Control and Indicating Equipment**

AW-CFP2166-4  
AW-CFP2166-8  
AW-CFP2166-12  
AW-CFP2166-16  
AW-CFP2166-20  
AW-CFP2166-24  
AW-CFP2166-28  
AW-CFP2166-32

**Standards**

EN 54-2:1997 + A1:2006

EN 54-4:1997 + A1:2002 + A2:2006

(refer to Appendix for details)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

11 June 2021

Date of Issue

06 March 2019

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd, and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

### Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.										
AW- CFP2166-4	<p>4 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table border="0"> <tr> <td>Asenware Main Board</td> <td>Main Board</td> </tr> <tr> <td>Asenware Interface Board</td> <td>Interface Board</td> </tr> <tr> <td>Asenware PSE</td> <td>Power and Charger Board</td> </tr> <tr> <td>Asenware Zonal Board</td> <td>1 x 4 Zone Board</td> </tr> <tr> <td>Asenware EMI</td> <td>EMI Board</td> </tr> </table> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	Asenware PSE	Power and Charger Board	Asenware Zonal Board	1 x 4 Zone Board	Asenware EMI	EMI Board	1395c/01
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											
Asenware PSE	Power and Charger Board											
Asenware Zonal Board	1 x 4 Zone Board											
Asenware EMI	EMI Board											
AW- CFP2166-8	<p>8 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table border="0"> <tr> <td>Asenware Main Board</td> <td>Main Board</td> </tr> <tr> <td>Asenware Interface Board</td> <td>Interface Board</td> </tr> </table>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	1395c/02						
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

  
Signed for BRE Global Ltd

P Halligan  
Verifier

11 June 2021  
Date of Issue

06 March 2019  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



**bre**

### Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.
	<p>Asenware PSE            Power and Charger Board</p> <p>Asenware Zonal Board    2 x 4 Zone Boards</p> <p>Asenware EMI            EMI Board</p> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	
AW-CFP2166-12	<p>12 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <p>Asenware Main Board    Main Board</p> <p>Asenware Interface Board    Interface Board</p> <p>Asenware PSE            Power and Charger Board</p> <p>Asenware Zonal Boards    3 x 4 Zone Boards</p> <p>Asenware EMI            EMI Board</p>	1395c/03

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

  
Signed for BRE Global Ltd

P Halligan  
Verifier

11 June 2021  
Date of Issue

06 March 2019  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of The Building Research Establishment Ltd.



**bre**

### Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.										
	<p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>											
AW-CFP2166-16	<p>16 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table border="0"> <tr> <td>Asenware Main Board</td> <td>Main Board</td> </tr> <tr> <td>Asenware Interface Board</td> <td>Interface Board</td> </tr> <tr> <td>Asenware PSE</td> <td>Power and Charger Board</td> </tr> <tr> <td>Asenware Zonal Boards</td> <td>4 x 4 Zone Boards</td> </tr> <tr> <td>Asenware EMI</td> <td>EMI Board</td> </tr> </table> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	Asenware PSE	Power and Charger Board	Asenware Zonal Boards	4 x 4 Zone Boards	Asenware EMI	EMI Board	1395c/04
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											
Asenware PSE	Power and Charger Board											
Asenware Zonal Boards	4 x 4 Zone Boards											
Asenware EMI	EMI Board											

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

  
Signed for BRE Global Ltd

P Halligan  
Verifier

11 June 2021  
Date of Issue

06 March 2019  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



**bre**

### Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.
	7.10.2 Output type B (option with requirement) 8.9 Output to fault warning routing equipment (option with requirements)  Note: 1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.	
AW- CFP2166-20	20 Zone Conventional Control and Indicating Equipment  Incorporating the following units: Asenware Main Board      Main Board Asenware Interface Board      Interface Board Asenware PSE      Power and Charger Board Asenware Zonal Boards      5 x 4 Zonal Boards Asenware EMI      EMI Board  Certified with the following options with requirements from EN54-2: 1997 + A1: 2006: 7.8 Output to fire alarm devices (option with requirements) 7.9.1 Output to fire alarm routing equipment (option with requirements) 7.10.1 Output type A (option with requirement) 7.10.2 Output type B (option with requirement) 8.9 Output to fault warning routing equipment (option with requirements)  Note: 1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.	1395c/05

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

  
Signed for BRE Global Ltd

P Halligan  
Verifier

11 June 2021  
Date of Issue

06 March 2019  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XK  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



**bre**

### Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.										
AW- CFP2166-24	<p>24 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table border="0"> <tr> <td>Asenware Main Board</td> <td>Main Board</td> </tr> <tr> <td>Asenware Interface Board</td> <td>Interface Board</td> </tr> <tr> <td>Asenware PSE</td> <td>Power and Charger Board</td> </tr> <tr> <td>Asenware Zonal Boards</td> <td>6 x 4 Zone Boards</td> </tr> <tr> <td>Asenware EMI</td> <td>EMI Board</td> </tr> </table> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	Asenware PSE	Power and Charger Board	Asenware Zonal Boards	6 x 4 Zone Boards	Asenware EMI	EMI Board	1395c/06
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											
Asenware PSE	Power and Charger Board											
Asenware Zonal Boards	6 x 4 Zone Boards											
Asenware EMI	EMI Board											
AW- CFP2166-28	<p>28 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <table border="0"> <tr> <td>Asenware Main Board</td> <td>Main Board</td> </tr> <tr> <td>Asenware Interface Board</td> <td>Interface Board</td> </tr> </table>	Asenware Main Board	Main Board	Asenware Interface Board	Interface Board	1395c/07						
Asenware Main Board	Main Board											
Asenware Interface Board	Interface Board											

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

  
Signed for BRE Global Ltd

P Halligan  
Verifier

11 June 2021  
Date of Issue

06 March 2019  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of The Building Research Establishment Ltd.



**bre**

### Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.
	<p>Asenware PSE            Power and Charger Board</p> <p>Asenware Zonal Boards    7 x 4 Zone Boards</p> <p>Asenware EMI            EMI Board</p> <p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	
AW-CFP2166-32	<p>32 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <p>Asenware Main Board    Main Board</p> <p>Asenware Interface Board    Interface Board</p> <p>Asenware PSE            Power and Charger Board</p> <p>Asenware Zonal Boards    8 x 4 Zone Boards</p> <p>Asenware EMI            EMI Board</p>	1395c/08

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

  
Signed for BRE Global Ltd

P Halligan  
Verifier

11 June 2021  
Date of Issue

06 March 2019  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of The Building Research Establishment Ltd.



**bre**

Appendix to Certificate No: 1395c

Issue: 03

## Zhongshan Guta Fire Equipment Technology Co Ltd

Certified Product	Description	LPCB Ref.No.
	<p>Certified with the following options with requirements from EN54-2: 1997 + A1: 2006:</p> <p>7.8 Output to fire alarm devices (option with requirements)</p> <p>7.9.1 Output to fire alarm routing equipment (option with requirements)</p> <p>7.10.1 Output type A (option with requirement)</p> <p>7.10.2 Output type B (option with requirement)</p> <p>8.9 Output to fault warning routing equipment (option with requirements)</p> <p>Note:</p> <p>1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.</p>	



This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*P Halligan*  
Signed for BRE Global Ltd

P Halligan  
Verifier

11 June 2021  
Date of Issue

06 March 2019  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



**bre**



Appendix to Certificate No: 1395c

Issue: 03

**Zhongshan Guta Fire Equipment Technology Co Ltd****Alternative Model No./Label**

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
1395c/02	AW-CFP2166-8	FF CF608	Finder Yangın Güvenlik Elektronik Sistemler A.Ş	1395c-(cl-1)



This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

*P Halligan*  
Signed for BRE Global Ltd

P Halligan  
Verifier

11 June 2021  
Date of Issue

06 March 2019  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre